



## DEPARTMENT OF PUBLIC WORKS

1600 – 13th Avenue South  
Kelso, WA 98626  
TEL (360) 577-3030  
FAX (360) 636-0845  
Washington Relay Service 711 or (888) 833-8633

[www.co.cowlitz.wa.us/publicworks/](http://www.co.cowlitz.wa.us/publicworks/)

### Board of County Commissioners

Arne Mortensen	District 1
Dennis P. Weber	District 2
Joe Gardner	District 3

## Camelot Subdivision Water System

(WATER SYSTEM I.D. NO. 10805M)

### 2019 Water Quality Report

*(Required by 1996 Federal Safe Drinking Water Act Amendments)*

#### **Summary**

The following report provides detailed information concerning the Camelot Water System which serves the Camelot Community. The quality of drinking water is sampled and tested from January 1, 2019 through December 31, 2019. The Camelot Water System provides domestic drinking water to 142 people with 53 connections. This system met or exceeded all federal and state drinking water standards and testing requirements during 2019. This report is provided to each of the customers via paper copy upon request and at the Cowlitz County website URL address: <http://wa-cowlitzcounty.civicplus.com/index.aspx?nid=1520>. If you have any questions about this report or the water system, please contact Cowlitz County by telephone at (360) 577-3030 or via email at [publicworks@co.cowlitz.wa.us](mailto:publicworks@co.cowlitz.wa.us), or Southwest Region Tumwater 360-236-3030 email: [ccr.swro@doh.wa.gov](mailto:ccr.swro@doh.wa.gov).

#### **Water Source Information**

The water system withdraws water from a 114 foot deep class "A" well located at the north end of the subdivision. This well has a rated capacity of 40 gallons per minute.

#### **Water Treatment Information**

Liquid chlorine is added to the well water as a disinfectant. Sufficient chlorine is added to kill any bacteria from the well and to maintain a residual level of chlorine in the distribution system. The residual chlorine kills bacteria that could enter the system through the storage reservoir or water line breaks in the distribution system. The reservoir tank was vacuumed clean in summer of 2014 and audited by Department of Environment Health in 2015.

#### **Water Sampling**

Your water is sampled on a regular basis according to both State and Federal regulations. The purpose of the sampling is to ensure that treatment methods are adequate. It also insures that harmful substances don't exceed regulated amounts and identifies if they are present or entered the water supply. In 2018 we sampled for the following constituents below.

## Annual Testing

This system was tested on June 12, 2019 for THM's and HAA5s. The chart in this report provides representative analytical results of water samples, collected from your system. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk.

ELEMENT	VIOLATION Y/N	RESULTS	UNIT	MCLG	MCL	TYPICAL SOURCE OF CONTAMINANT
NIT	N	1.16	Mg/L	NA	10	Nitrate & Nitrite fertilizer runoff

Parts per billion (ppb) or Micrograms per liter (ug/l) - one part per billion corresponds to a single penny in \$10,000,000.

**Maximum Contaminant Level or MCL:** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal or MCLG:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

### General Information about Contaminants

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

**Microbial contaminants**, such as viruses, parasites, and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife.

**Inorganic contaminants**, such as salts and metals, which can occur naturally or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, and farming.

**Pesticides and herbicides**, which may come from various sources such as agriculture, urban stormwater runoff, and residential uses.

**Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production. They can also come from gas stations, urban stormwater runoff, and septic systems.

**Radioactive contaminants**, which can occur naturally or result from oil and gas production and mining activities.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Cowlitz County Public Works is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.